

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM  
**LISTING SERVICE**

**LISTING No.** 7320-1501:142

Page 1 of 1

**CATEGORY:** Speakers

**LISTEE:** Edwards Signaling, 90 Fieldstone Ct., Cheshire, CT 06410  
Contact: David Mazur (203) 699-3155 FAX (203) 699-3108

**DESIGN:** Models EG4-S2, EG4R-S2, EG4-S7, EG4R-S7, EG4F-S7, EG4RF-S7, EG4F-S2, EG4RF-S2, \*EGC-S2, \*EGCF-S2, \*EGC-S7, and \*EGCF-S7 speakers.  
Models EG4-S2VM, EG4R-S2VM, EG4-S7VM, EG4R-S7VM, EG4F-S2VM, EG4RF-S2VM, EG4F-S7VM, EG4RF-S7VM, \*EGC-S2VM, \*EGCF-S2VM, \*EGC-S7VM, and \*EGCF-S7VM speaker strobes.  
Models EG4B and EG4RB speaker enclosure backbox. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 25 Vrms or 70 Vrms  
¼ W, ½ W, 1 W, 2 W  
G4 Candela: 15cd, 30cd, 75cd, 110cd  
\*GC Candela: 15cd, 30cd, 75cd, 95cd

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical & candela rating, and UL label.

**APPROVAL:** Listed as speakers and speaker/strobes for use with separately listed compatible fire alarm control units. Speakers with a strobe are suitable for the hearing impaired. For indoor use only. Refer to listee's Installation Instruction Manual for details.

If the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation signal (for total evacuation) in accordance with NFPA 72, 1999 Edition is required, the control units must be used with appliances that can generate the temporal pattern signal.

**XLF:** 7320-1591:211

\*Rev. 12-03-03



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **DECEMBER 3, 2003**

*Listing Expires **June 30, 2004***

Authorized By: **DIANE K. AREND, Senior Deputy  
Program Manager**